

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-08227
Name of Facility: Ernest R Graham k-8 Academy
Address: 7330 W 32 Avenue
City, Zip: Hialeah 33018

Type: Public School
Owner: M-DCSB Food and Nutrition
Person In Charge: Mayra Alfaro Phone: 305-825-2122

**Correct By: Next Inspection
Re-Inspection Date: None**

Inspection Information

Purpose: Routine
Inspection Date: 5/8/2017

Begin Time: 01:00 PM
End Time: 02:30 PM

Additional Information

FEMALES 690 CENSUS 1405
MALES 715

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

Violation Markings

SCHOOL SANITATION	11. Cleanliness & Repair	22. Solid Waste
1. School Site	12. Toilet Facilities	VECTOR/VERMIN CONTROL
2. Playground Equipment	13. Separation of Sexes	23. Infestation/Control
3. Athletic Equipment	14. Fixture Ratio	24. Brush/Trash
BUILDINGS	15. Handwash Facilities	25. Water Collection/Drainage
4. Construction	16. Showers/Fixtures	SAFETY
5. Maintenance & Repair	17. Shower Water Temp.	26. First Aid Kit
X 6. Lighting/Foot-Candles	WATER SUPPLY	FOOD
7. Heating, Ventilation, A/C	18. Installed/Operated/Maintained	27. Food Insp. Rpt.
8. Natural Ventilation	X 19. Drinking Fountains	OTHER
9. Mechanical Ventilation	20. Approved Source	28.
SANITARY FACILITIES	LIQUID/SOLID WASTE	29.
10. Provided/Accessible	21. Sewage Disposal	

General Comments

No General Comments Available
Email Address(es): malfaro@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #6. Lighting/Foot-Candles

Replace burnt light bulb in bathroom 109

CODE REFERENCE: Lighting/Foot-Candles 64E-13.004(4)(a-d). Illumination in all instructional spaces shall be designed to provide a minimum of forty (40) foot-candles glare free at normal task level. Fixtures shall be so located that there will be uniform (within ten (10) foot-candles) illumination suitable for the activities conducted therein. All required illumination shall be designed so that the failure of any single unit, such as the burning out of an electric bulb will not leave any occupied area or means of egress in darkness. Illumination of chalkboards and other visual aids shall be designed to eliminate glare and shadows.

Violation #19. Drinking Fountains

Repair non-working water fountain first floor.

Change or clean the drinking fountains head, there is unhygienic dirt built in located in classrooms 276 and 261

CODE REFERENCE: Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.

Inspection Conducted By: Diaaiden Alwadi (31113)

Inspector Contact Number: Work: (305) 623-3500 ex.

Print Client Name:

Date: 5/8/2017

Inspector Signature:

Handwritten signature of the inspector, Diaaiden Alwadi.

Client Signature:

Handwritten signature of the client, Ernest R. Graham.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-13413
Name of Facility: Ernest R Graham Satellite
Address: 7330 W 32 Avenue
City, Zip: Hialeah 33018

**Correct By: Next Inspection
Re-Inspection Date: None**

Type: Public School
Owner: M-DCSB Food and Nutrition
Person In Charge: Mayra Alfaro Phone: 305-825-2122

Inspection Information

Purpose: Routine
Inspection Date: 5/8/2017

Begin Time: 02:30 PM
End Time: 04:00 PM

Additional Information

FEMALES 690 CENSUS 1405
MALES 715

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

Violation Markings

SCHOOL SANITATION	11. Cleanliness & Repair	22. Solid Waste
1. School Site	X 12. Toilet Facilities	VECTOR/VERMIN CONTROL
2. Playground Equipment	13. Separation of Sexes	23. Infestation/Control
3. Athletic Equipment	14. Fixture Ratio	24. Brush/Trash
BUILDINGS	X 15. Handwash Facilities	25. Water Collection/Drainage
4. Construction	16. Showers/Fixtures	SAFETY
5. Maintenance & Repair	17. Shower Water Temp.	26. First Aid Kit
6. Lighting/Foot-Candles	WATER SUPPLY	FOOD
7. Heating, Ventilation, A/C	18. Installed/Operated/Maintained	27. Food Insp. Rpt.
8. Natural Ventilation	19. Drinking Fountains	OTHER
9. Mechanical Ventilation	20. Approved Source	28.
SANITARY FACILITIES	LIQUID/SOLID WASTE	29.
10. Provided/Accessible	21. Sewage Disposal	

General Comments

No General Comments Available

Email Address(es): malfaro@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #12. Toilet Facilities

Provide soap, paper towel, toilet paper bathrooms 332, and 002

CODE REFERENCE: Toilet Facilities 64E-13.004(6)(a). Toilet facilities shall be accessible under continuous roof cover from all student occupied spaces. In group toilet rooms a partition shall be placed between each water closet. Each compartment shall have a door. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block the occupants from view. Entrance doors shall be self-closing.

Violation #15. Handwash Facilities

Repair non-working air hand dryer in bathrooms 332

CODE REFERENCE: Handwash Facilities 64E-13.004(6)(b). Handwashing facilities shall be located within or adjoining each toilet room. Soap dispensers shall be provided at all wash basins and liquid or powdered soap shall be used. Individual towels, preferably paper shall be used. Use of common or public towels is prohibited. Hot-air hand drying devices

Inspection Conducted By: Diaaiden Alwadi (31113)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 5/8/2017

Inspector Signature:

Handwritten signature of the inspector, Diaaiden Alwadi.

Client Signature:

Handwritten signature of the client, Ernest R Graham.